

TESCO Products Inc.

FILE NO: 20859
LAB. NO: T-03-451

11/05/2003

SUBJECT:

12" x 12" Terrazzo, Marble and Granite Tiles sealed
with **TESCO Crystal Seal II**

SPECIFICATION:

ASTM C1028 (Modified per Ceramic Tile Institute)

SOURCE:

Submitted to Laboratory by Tesco Products

STATIC COEFFICIENT OF FRICTION (ASTM C 1028 MODIFIED)

<u>TEST CONDITION</u>	<u>AREA</u>	<u>AVERAGE</u>	<u>COEFFICIENT</u>
dry leather	Terrazzo	36.80	0.73
	Marble	33.05	0.65
	Granite	32.70	0.67
dry rubber	Terrazzo	50.30	1.01
	Marble	50.00	1.03
	Granite	50.05	1.02
wet leather	Terrazzo	39.05	0.78
	Marble	35.50	0.70
	Granite	35.20	0.72
wet rubber	Terrazzo	43.70	0.86
	Marble	42.05	0.84
	Granite	41.70	0.85

REQUIREMENT: The Ceramic Tile Institute identifies tile in the following 3 categories:

1. slip resistant 0.60 or greater
2. conditionally slip resistant 0.50-0.60
3. questionable less than 0.50

25601 Avenue Stanford, Valencia, Ca. 91355
sales@tescoproductsinc.com
661-257-0153 661-257-0248 fax